



**MINISTRY OF WATER AND ENVIRONMENT
NATIONAL WATER QUALITY REFERENCE LABORATORY - ENTEBBE**

Certificate of Analysis

Client Name : Spouts of Water
 Client Address : P.O.Box 12042, Kampala
 Sample type and condition : Tap Water Sample before and after filtration
 Sample by : Client
 Date Sampled : 18th May 2022 Date received : 18th May 2022
 Analysis Start date : 18th May 2022 Analysis Completion date : 24th May 2022

Ref: NWQRL22 – 0051

TEST RESULTS

Source Name			Tap water before	Tap water after	Potable water standards (DEAS12:2018 Maximum permissible for Natural potable Water)
District			Filtration	Filtration	
Lab Identifier code			Entebbe	Entebbe	
			E22/03907	E22/03908	
Parameter	Method Code	Units	Test Results		
Turbidity (NTU)	TM/C-03/01	NTU	1.98	2.46	25
pH	TM/C-01/01	units	7.5	5.9	5.5-9.5
Electrical Conductivity	TM/C-02/01	µS/cm	105	63	2500
Total dissolved solids	TM/C-02/02	mg/l	74	44	1500
Total Coliforms	TM/M-01	CFU/100mls	157	<1	<1
Ecoli	TM/C-08/01	CFU/100mls	21	<1	<1

Note : 1. This certificate shall not be reproduced without approval of the Laboratory.


2. * Method not accredited by SADCAS
3. **Test result from sub-contracted Laboratory.
4. Analysis site is National Water Quality Reference Laboratory-Entebbe

Disclaimer

- These results relate to the sample as received.
- Details of the sample with respect to source and representativeness have not been verified by the laboratory.
- This certificate of analysis does not substitute certification of a business or product by the relevant authority.

Checked by:

Technical signatory



Water Quality Management Department
 Directorate of Water Resources Management
 Waterquality.laboratory@mwe.go.ug
 Plot 17, John Babiha Road, Entebbe
 Tel: 041-321342

010383